





OPTION 1 CONDUIT PLUGS

THE FOLLOWING ITEMS SHALL BE USED FOR CIRCUMSTANCES REQUIRING A CONDUIT SEAL PARTICULARLY FOR WATER INGRESS INCLUDING INDOOR SUBSTATION SWITCHING STATION AND INTAKE STATION. ITEMS TO BE APPLIED AT ENTRY POINT TO SOURCE END

ALL PLUGS COME WITH SEGMENTED RINGS TO FIT SPECIFIC CABLE DIAMETER. FOLLOW ALL INSTRUCTIONS INCLUDED IN THE PACKAGING.

OPTION 1.						
ITEM	ITEM NUMBER	CONDUIT DIAMETER	CABLE DIAMETER RANGE	NUMBER OF CABLES	USAGE	MATERIAL
1	503123	100mm	8-30mm	4	LV DISTRIBUTION	POLYMERIC
2	503121	150mm	25-54mm	3	HV CABLES EXCEPT 630sqmm	POLYMERIC
3	503122	150mm	12-75mm	1	400 AND 630sqmm HV CABLES	STAINLESS STEEL

OPTION 2.						
ITEM	ITEM NUMBER	CONDUIT DIAMETER	CABLE DIAMETER RANGE	NUMBER OF CABLES	USAGE	MATERIAL
1	*	*	*	*	*	*

3 SUPERSEDED 2 TITLEBLOCK & DRAWING NUMBER FORMATTED 1 AMENDED TO INCLUDE DUCT SEALANT 0 ISSUED FOR CONSTRUCTION					 NORTHERN TERRITORY	DES	A. TAYLOR	POWER STANDARD DRAWING		
	DRN	A. TAYLOR								
	CKD	I. BASHIR	CONDUIT ACCESSORIES, CONDUIT SEALING OPTION							
	APPD	B. CHEUNG								
	SCALE	N. T. S.								
ISSUED	FEB' 15	A3	DRAWING NUMBER	S02-01-09-04						
ALL DIM. IN mm										
DRAFTING STANDARD TO A.S.1100						CAD PRODUCT - DO NOT AMEND MANUALLY			AMDT	