

SINGLE PHASE & RTE PACKAGE SUBSTATION					
TRF. kVA	H.V. CURRENT LIMIT ELX FS		H.V. CURRENT LIMIT ELX FS		ITEM NUMBER H.V. FUSE
	11kV				
	1 ϕ		3 ϕ		
	H.V.	L.V. MAX	H.V.	L.V. MAX	
50	15*	100	--	--	500771
75	25	100	--	--	9845
300	--	--	25	400	11098
500	--	--	40	500	247650

NOTES: *15A BAYONET FUSE LINK ADOPTED AS STANDARD FOR BOTH G.E. & TYRE 1 ϕ TRANSFORMERS IN THE URD SYSTEM.

						DES	A.GREENWOOD	POWER STANDARD DRAWING	
						DRN	A.SCHMID	DESIGN DATA	
						CKD	A.GREENWOOD	FUSE CHARTS - MAJOR CENTRES	
						APPD	B.T.KENT	11KV RMU/SINGLE PHASE &	
						SCALE	N.T.S.	RTE SUBSTATIONS	
						ISSUED	NOV'91	A3	DRAWING NUMBER
						ALL DIM. IN mm			
						DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	
								AMDT	

7 TITLEBLOCK & DRAWING NUMBER FORMATTED
6 REMOVED FUSE & MCCB TABLED
5 MCCB TYPE CHANGED
4 REDRAWN, DRIESCHER MINEX RMU ADDED
3 REDRAWN IN CAD, 75KVA 1 PHASE SUBSTATION, DRIESCHER SWITCHGEAR ADDED
2 TABLES AMENDED

K.T.	APR'19	C.C.	C.C.
K.T.	MAY'16	B.C.	B.C.
A.T.	AUG'14	B.C.	B.C.
A.S	NOV'12	A.T.	S.C.
J.C.	JUN'10	A.T.	S.C.
J.C.	MAR'06	A.T.	S.C.



NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					