



**DETAIL OF SLEEVE**  
95sq.mm SLEEVE SHOWN.

**NOTES:**

1. CABLE INSULATION TO BE REMOVED TO DIMENSION SHOWN ON LINK AND FULLY INSERTED INTO LINK BEFORE COMPRESSION.
2. JOINTS TO BE MADE WITH INDIVIDUAL CORE JOINTS STAGGERED MIN 150mm.
4. LINK TO HAVE EMBOSSED ON THE INSULATION:
  - STRIPPING LENGTH,
  - COMPRESSION DIE SIZE A/F,
  - NUMBER, LOCATION AND SEQUENCE OF COMPRESSIONS.
5. USE TERMINATION LUG COMPRESSION 504381 BIMETAL INSULATED. S02-01-02-22
6. TO COMPLY WITH PWC SPECIFICATION STSP 05-013.

**TABLE 1: ITEM DETAILS**

ITEM REF.	CONDUCTOR C.S.A (sq.mm)	RATED TENSION (kN)	HEX. DIE A/F (mm)	ITEM NUMBER
1	95	16.8	215	229039
2	150	7	215	415590

9	REMOVED ROW 2 ON THE TABLE. ADDED NOTE 5.	J.R.	SEP'24	J.R.	B.B.
8	AMENDED ITEM 3. ADDED NOTE 5.	P.BH.	NOV'22	B.V.	B.C.
7	REFORMATTED TABLE & TEXT. CHANGED ITEM 2 A/F. REMOVED COLOURS & NOTE 3	A.N.	AUG'21	A.N.	B.V.
6	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	DEC'19	C.C.	C.C.
5	150sqmm VERSION ADDED	K.T.	MAR'12	B.C.	S.C.
4	AMENDED NOTES	K.T.	FEB'08	B.C.	S.C.
3	TABLE AND NOTE 4 AMENDED	K.T.	NOV'99	G.H.	F.R.
NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					



DES	A.B.	POWER STANDARD DRAWING			
DRN	A.DAVIS	<b>LV AERIAL BUNDLED CABLE LINK - COMPRESSION</b>			
CKD	R.INNES				
APPD	F.ROBSON				
SCALE	N.T.S.				
ISSUED	MAY'98	<b>A3</b>	<b>DRAWING NUMBER</b>	<b>S04-01-02-17</b>	
ALL DIM.	IN mm			<b>9</b>	
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY		

