


**APPLICATION:**

ITEM 1 - IS USED TO CONVERT AN 81 ID SPIGOT TO A 76 OD SPIGOT.

**NOTES:**

1. ALL WORKMANSHIP AND MATERIALS TO BE IN ACCORDANCE WITH AS 3678.
2. ALL WELDING AND WELD PREPARATION TO BE IN ACCORDANCE WITH AS 1554. FILLET WELDS TO BE 6mm, UNLESS NOTED OTHERWISE.
3. ALL ROUGH OR BURRED EDGES ARE TO BE DRESSED CLEAN.
4. BOLTS TO BE METRIC, PROPERTY CLASS 4.6 IN ACCORDANCE WITH AS 1111.
5. AFTER FABRICATION AND CLEANING UP ALL COMPONENTS ARE TO BE ACID DESCALED AND HOT DIP GALVANIZED IN ACCORDANCE WITH PAWA STANDARD TECHNICAL SPECIFICATION NO STS 029.
6. CIRCULAR PIPE COMPONENTS TO COMPLY WITH AS 1163.



**ITEM 1 - SPIGOT ADAPTOR**

ITEM NUMBER 230755

- 4 OBSOLETE
- 3 TITLEBLOCK & DRAWING NUMBER FORMATTED
- 2 CHANGES TO DIMENSIONS.
- 1 REDRAWN. APPLICATION NOTES ADDED.

A.N.	AUG'21	C.C.C.	B.V.
K.T.	FEB'19	C.C.	C.C.
R.G.I	JUN'98	-	F.R.R
GMCK	JAN'91	-	N.S.

**PowerWater**  
NORTHERN TERRITORY

DES	N.S.	POWER STANDARD DRAWING	
DRN	GMCK	BRACKET SPIGOT ADAPTOR 5.5 POST TOP COLUMN	
CKD	N.STUBBS		
APPD	B.T.KENT		
SCALE	1:2	<b>A3</b>	<b>DRAWING NUMBER</b> S03-01-03-07
ISSUED	JAN'91		
ALL DIM.	IN mm	DRAFTING STANDARD TO A.S.1100	
CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT	

NO	DESCRIPTION	DRN	DATE	CKD	APPD
AMENDMENTS					