



NOTES

1. ALL WELDS AND BLACK METAL SURFACES TO BE CLEANED AND COATED WITH COLD GALVANISING COMPOUND.
2. ALL WELDING AND WELD PREPARATION TO BE IN ACCORDANCE WITH AS 1554. SYMBOLS COMPLY WITH AS 1101 PART 3.
3. BOTH FLANGES OF BRACKET TO BE WELDED TO POLE WITH STANDARD FULL STRENGTH STRUCTURAL WELDS.
4. BOND NEUTRAL TO POLE VIA RAMSET STUD
5. EARTH CONDUCTOR SIZE TO BE 16 sq mm STRANDED COPPER.
6. POLARITY OF NEUTRAL/EARTH CONNECTION TO BE CONFIRMED DURING COMMISSIONING AND AFTER MAINTENANCE.

ITEM	QTY.	DESCRIPTION	ITEM NUMBER	DRG REF
6	1	FUSED MAINS CONNECTION BOX	6866	
5	1	OUTREACH TAPERED STEEL		S03-01-01-10
4	2	HOOK STRAP	9324	S01-01-04-07
3	3	BOLT M16x50 GALV. STEEL C/W NUT	114504	
2	1	MOUNTING BRACKET	8664	S03-01-03-01
1	1	STEEL COLUMN 10.7 METRE	8920	S03-01-01-03

MATERIAL SCHEDULE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
5	OBSOLETE	A.N.	AUG'21	C.C.C.	B.V.
4	TITLEBLOCK & DRAWING NUMBERS FORMATTED	K.T.	FEB'19	C.C.	C.C.
3	NOT FOR NEW CONSTRUCTION	I.B.	SEP'16	A.T.	I.B.
2	NOTES 3, 4, 5 & 6 ADDED	J.A.L.	3/95	A.G.B.	P.J.D.
1	NOTES ADDED	R.T.F.	9/90	N.S.	N.S.
AMENDMENTS					



DES	N.S.	POWER STANDARD DRAWING		
DRN	R.T.F.	BRACKET TAPERED OUTREACH ASSEMBLY DETAILS		
CKD	N.S.			
APPD	B.K.			
SCALE	1:6			
ISSUED	MAY'98	A3	DRAWING NUMBER	S03-01-03-08
ALL DIM.	IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		