


3RD ANGLE — DO NOT SCALE — REPORT ANY ERRORS. OMISSIONS TO DRAFTING OFFICE



NOTE

- CONTROL GEAR ASSEMBLY SHALL INCLUDE THE FOLLOWING —
 CHOKE FERGUSON TYPE MF400TA FOR 400WATT.
 OR TYPE MF250TA FOR 250WATT.
 CAPACITOR

TECHNICAL DATA

FOR OUTDOOR USE UNDER EXTREME TROPICAL CONDITIONS AS 1158
SPECIAL CRITERIA FOR N.T. PUBLIC LIGHTING LANTERNS:

1. DELETION OF BUILT IN FUSE WITHIN LANTERN.
2. PROVISION OF REMOVABLE CONTROL GEAR TRAY.
3. PROVISION OF QUICK DISCONNECT PLUG BETWEEN PORCELAIN BLOCK AND REMOVABLE TRAY. (SIMILAR TO UTILUX M/N 1545-2)
4. EARTH ATTACHMENT TO BODY OF LANTERN.
5. LANTERN TO COMPLY WITH AS 3771 FOR CATEGORY 'A' ROAD LUMINAIRES.

ITEM	LANTERN	ITEM No	A.E.I. CAT No
1	250W	11650	SL 4064 / 25
2	400W	11668	SL 4064 / 40
3	VISOR	6601	TAG No. 2

ITEM No	QTY.	DESCRIPTION	DRG. No
9	1	GASKET CONT. GEAR ASSY. NEOPRENE	---
8	1	GASKET BOWL NEOPRENE	---
7	1	HOLDERS LAMP PORCELAIN GES.	---
6	1	CHOKE 250W FERGUSON MF250 TA.	---
5	1	CHOKE 400W FERGUSON MF400TA.	---
4	1	CAPACITOR 15 MFD. FOR 250W	---
3	1	CAPACITOR 20 MFD. FOR 400W	---
2	1	VISOR ACRYLIC CAT N°	---
1	1	REFLECTOR ALUMINIUM CAT N°	---

MATERIALS SCHEDULE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
7	OBSOLETE				
6	TITLEBLOCK & DRAWING NUMBER FORMATTED	A.N.	AUG'21	C.C.C.	B.V.
5	NOTES AMENDED	K.T.	MAY'19	C.C.	C.C.
4	ITEM 3 - STOCK CODE 6601 ADDED	R.T.F	FEB'91	-	-
3	NOTE 6 ADDED	R.T.F	09/89	-	-
2	TITLE & DRAWING NUMBER CHANGED	-	06/89	-	-
1	ITEM & STOCK CODES ADDED	W.T.	12/87	-	-
			01/87	-	-

PowerWater
 NORTHERN TERRITORY

DES	G. McS	POWER STANDARD DRAWING	
DRN	RPP	LANTERN & LAMPS	
CKD	G. McS	MAJOR ROADS	
APPD	-	MERCURY VAPOUR 250-400W	
SCALE	-	A3	DRAWING NUMBER S03-01-04-07
ISSUED	20/02/86		
ALL DIM.	IN mm		
DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY

