



NOTES:

1. ALL WORKMANSHIP AND MATERIALS SHALL BE IN ACCORDANCE WITH AS3679.
2. ALL ROUGH AND BURRED EDGES ARE TO BE DRESSED CLEAN.
3. BRACKET TO BE HOT DIP GALVANISED, WHEREBY COMPONENTS ARE TO BE EVEN AND FREE OF LUMPS AND BUILD-UP AND TRUE TO SHAPE AFTER GALVANISING. COMPONENTS WILL BE TESTED IN ACCORDANCE WITH AS1650.
4. BRACKET TO BE USED FOR DOUBLE MOUNTING OF LV-ABC FUSE-SWITCH-DISCONNECTOR REFER S04-01-03-05.
5. FABRICATION TO COMPLY WITH PWC SPECIFICATION STSP 01-002.

ITEM NUMBER : 207183

MATERIAL : 40 x 8 FLAT

NO	DESCRIPTION	DRN	DATE	CKD	APPD
5	UPDATED HOLES TO SLOTTED HOLES. ADDED NOTE 5.	P.BH.	JUN'22	P.BH.	B.V.
4	UPDATED DIMENSIONS TO SUIT 400A UNIT. UPDATED STANDARDS REFERENCE. ADDED NOTE 4.	A.N.	AUG'21	A.N.	B.V.
3	TITLEBLOCK & DRAWING NUMBERS FORMATTED	C.C.	AUG'19	M.S.	C.C.
2	ITEM NUMBER CHANGED	A.S.	MAY'07	R.S.	S.C.
1	ITEM NUMBER ADDED	A.S.	JAN'04	R.C.	M.B.
0	ISSUED FOR CONSTRUCTION, REPLACES S04-01-02-01	A.S.	SEP'02	M.B.	M.B.



DES	M. BOCK	POWER STANDARD DRAWING		
DRN	A. SCHMID	LINE HARDWARE LV-ABC TERMINATION/BOLTED CONNECTIONS FUSE SWITCH BRACKET		
CKD	M. BOCK			
APPD	M. BOCK			
SCALE	1 : 5			
ISSUED	SEPT'02	A3	DRAWING NUMBER	S04-01-02-04
ALL DIM. IN mm				
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY		AMDT