



ELEVATION
SCALE 1:25

- NOTES:**
- 300mm MINIMUM CLEARANCE IS REQUIRED BETWEEN SERVICE ARM AND CCO BOLT AND CLAMP ATTACHMENT POINT. WHEN NON-INSULATED OR BARE CABLES AND FITTINGS ARE ATTACHED TO THE SERVICE CROSSARM OR POLE AND WORK IS TO BE PERFORMED AT OR NEAR THE CCO BOLT/CLAMP ATTACHMENT POINT, PAWA IS TO BE CONTACTED TO 'MAT UP' ALL LIVE COMPONENTS.
 - CCO POWER SUPPLIES OR AMPLIFIERS ARE NOT TO BE ATTACHED TO AIRBREAK SWITCH, TRANSFORMER OR TEE-OFF POLES.

POWER STANDARD DRAWING		CCO (COMMUNICATIONS CABLE OWNER) POWER SUPPLY TYPICAL ARRANGEMENT		DRAWING NUMBER S01-02-02-28		AMDT 2	
DES	M. BOCK	DRN	R. INNES	APPD	P. DEWAR	SCALE	AS SHOWN
CKD	M. BOCK	ISSUED	08/10/96	ALL DIM.	IN mm	DRAWING STANDARD TO A.S.1100	
 NORTHERN TERRITORY							
SUPERSEDED		A.T. DEC '12		B.C. B.C.		FRR APPD	
TEXT 'CETV' CHANGED TO 'CCO'		RGI APR '97		MWB CKD		FRR APPD	
NO		DESCRIPTION		DATE		AMENDMENTS	

CAD PRODUCT - DO NOT AMEND MANUALLY