






| CADWELD CONNECTION TYPE  | ITEM REF. | MOULD DESCRIPTION                           | CADWELD PLUS MOULD PART NUMBER | MOULD PWC ITEM NUMBER | CADWELD METAL PART NUMBER | COLOUR OF WELD METAL PACKAGING | PWC ITEM NUMBER |
|--|-----------|---|--------------------------------|-----------------------|---------------------------|--------------------------------|-----------------|
|   | 1         | PARALLEL HORIZONTAL MOULD 70/70SQMM CABLE   | PTCY4Y4                        | 503457                | 115PLUSF20                | ORANGE                         | 503463          |
|  | 2         | PARALLEL HORIZONTAL MOULD 70/95SQMM CABLE   | PTCY5Y4                        | 503458                | 150PLUSF20                | DARK BLUE                      | 503464          |
|  | 3         | PARALLEL HORIZONTAL MOULD 95/95SQMM CABLE   | PTCY5Y5                        | 503459                | 200PLUSF20                | YELLOW                         | 503462          |
|  | 4         | PARALLEL HORIZONTAL MOULD 70/35SQMM CABLE   | PTCY4Y2                        | 503454                | 90PLUSF20                 | GRAY                           | 503466          |
|  | 5         | PARALLEL HORIZONTAL MOULD 120/70sqmm CABLE  | PTCY6Y4                        | 504405                | 150PLUSF20                | DARK BLUE                      | 503464          |
|  | 6         | PARALLEL HORIZONTAL MOULD 120/120sqmm CABLE | PTCY6Y6                        | 504397                | 250PLUSF20                | PURPLE                         | 504398          |
|   | 7         | 25mmX 3mm BAR TO 70sqmm CABLE               | LJCCAJY4                       | 503452                | 90PLUSF20                 | GRAY                           | 503466          |
|  | 8         | 40mm x 3mm BAR TO 120mm CABLE               | LJCCALY6                       | 504400                | 115PLUSF20                | ORANGE                         | 503463          |
|  | 9         | 25mm X 3mm BAR SPLICE                       | BBCCAJ                         | 503451                | 90PLUSF20                 | GRAY                           | 503466          |
|  | 10        | 40mm x 3mm BAR SPLICE                       | BBCCAL                         | 504399                | 115PLUSF20                | ORANGE                         | 503463          |



| ITEM REF. | OTHER EQUIPMENT               | PWC ITEM NUMBER |
|-----------|-------------------------------|-----------------|
| 11        | CADWELD PLUS CONTROL UNIT     | 503672          |
| 12        | MOULD HANDLE CLAMP            | 503461          |
| 13        | MOULD CLEANING BRUSH          | 503467          |
| 14        | MOULD SEALER                  | 503674          |
| 15        | CADWELD CERAMIC BLANKET       | 503719          |
| 16        | REPLACEMENT 4.6M CONTROL LEAD | 503760          |

**NOTES:**

- AUTHORISATION MUST BE OBTAINED FROM SERVICE DELIVERY CO-ORDINATOR BEFORE USING CADWELD PLUS EQUIPMENT.
- SURROUNDING AREA AND ENVIROMENT MUST BE ASSESSED TO DETERMINE THE SUITABILITY OF USING THE CADWELD PLUS EQUIPMENT.
- INSTRUCTIONS FOR USE ARE CONTAINED INSIDE EQUIPMENT CARRY CASE.
- ONLY CADWELD PLUS EQUIPMENT SHALL BE USED.
- POWER AND WATER OH&S AND WORKING PROCEDURES SHALL BE FOLLOWED WHILE USING CADWELD PLUS EQUIPMENT.
- GRAPHITE MOLDS MUST BE COOLED DOWN BEFORE RETURNING THEM TO THE CARRY CASE.

|   |  |  |  |                               |   |                                     |          |                                      |                |              |  |
|---|--|--|--|-------------------------------|---|-------------------------------------|----------|--------------------------------------|----------------|--------------|--|
| 3 ADDED ITEM REF. NUMBERS, CHANGED TABLE COLUMN HEADERS AND ITEMS 3, 8 & 10 WELD MATERIAL<br>2 120sqmm CABLE AND BAR ITEMS ADDED TO TABLE<br>1 TITLEBLOCK & DRAWING NUMBER FORMATTED<br>0 ISSUED FOR CONSTRUCTION |  |  |  |                               |  | DES                                 | B.CHEUNG | POWER STANDARD DRAWING               |                |              |  |
|   |  |  |  |                               |   | DRN                                 | A.TAYLOR | EARTHING<br>CADWELD PLUS CONNECTIONS |                |              |  |
|   |  |  |  |                               |   | CKD                                 | I.BASHIR |                                      |                |              |  |
|   |  |  |  |                               |   | APPD                                | B.CHEUNG |                                      |                |              |  |
|   |  |  |  |                               |   | SCALE                               | N.T.S.   | A3                                   | DRAWING NUMBER | S02-01-05-03 |  |
|   |  |  |  | ISSUED                        | MAY'16  |                                     |          |                                      |                |              |  |
|   |  |  |  | ALL DIM. IN mm                |   |                                     |          |                                      |                |              |  |
|   |  |  |  | DRAFTING STANDARD TO A.S.1100 |   | CAD PRODUCT - DO NOT AMEND MANUALLY |          |                                      |                | AMDT         |  |