



**NOTES :**

1. COVER-FORMED OR MOULDED RESIN PIGMENTED Nº 388 TO AS 2700
2. BOTTOM SKIRT OF COVER TO BE LOOSE FIT OVER FRAME 'H' TO FACILITATE EASE OF REMOVAL. 5mm CLEARANCE ALL AROUND, REFER TO DRAWING S02-01-03-03.
3. ADHERE DANGER SIGN TO COVER USING INDUSTRIAL ARALDITE (STOCK CODE 108456). SURFACES TO BE SCOURED BEFORE APPLYING THE ADHESIVE.
4. COMPLETE ITEM (ITEM 1) CONSISTS OF FIBERGLASS COVER PLUS ALL STEELWORK AS DETAILED ON DRG'S S02-01-03-02 AND S02-01-03-03.

4	1	SIGN 'DANGER - ELECTRICITY'	-	S02-01-08-03
3	1	SIGN PILLAR	-	S02-01-08-30
2	1	FIBREGLASS COVER (SPARES ONLY)	31138	-
1	1	COMPLETE ITEM (SEE NOTE 4)	11031	-
ITEM	QTY.	DESCRIPTION	ITEM NUMBER	DRAWING No.

NO	DESCRIPTION	DRN	DATE	CKD	APPD
6	CHANGED TO 'NOT FOR NEW CONSTRUCTION'	R.A.	JUL '21	C.C.C.	B.V.
5	SUPERSEDED	J.C.	NOV '10	A.T.	SC
4	ITEMS 3 & 4 ADDED. TITLE CHANGED	AS	AUG '06	RS	SC
3	REDRAWN ON CAD.	JAL	MAY '95	SCM	PJD

**PowerWater**

DES	J. HASSANEN	POWER STANDARD DRAWING	
DRN	R. HAIGH	DISTRIBUTION PILLARS	
CKD	G. Mc SHANAG	FUSED CABLE ENTRY	
APPD	I. CUK	COVERS, SIGNS AND GENERAL DETAILS	
SCALE	N.T.S.	A3	DRAWING NUMBER S02-01-03-06
ISSUED	BBB'86		
ALL DIM.	IN mm	DRAWING NUMBER S02-01-03-06	
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

