

CABLE TIES TO BE USED AS REQUIRED.

14mm HOLE FOR COMPRESSION LUG TO BE DRILLED ON SITE.

NEUTRAL TO BE BONDED TO EVERY POLE.

FOR CORRECT APPLICATION OF HOOK BOLTS REFER TO DRAWINGS S04-02-02-02 AND S04-02-02-04 FOR FULL DETAILS.

ACTIVE SERVICE TEE OFF TO BE BALANCED OVER THREE PHASES ON SUBSEQUENT POLES.

12	2	SERVICE CLAMP - STRAIN	-	S01-01-04-28			
11	2	J-HOOK WITH MOUNTING STRAP	9324	S01-01-04-07			
10	2	100A SERVICE FUSE ASSEMBLY	241109	S01-01-04-49			
9	2	SERVICE FUSE BRACKET	406802	S01-01-04-49			
8	1	CROSSARM BRACE 50x5 DURAGAL	298687	S01-01-04-38			
7	1	LV SERVICE CROSSARM 100x50x4 DURAGAL CC	298554	S01-01-02-11			
6	1	LUG COMPRESSION Cu 35 SQ.MM M12	156240	S02-01-02-11			
5	AR	CABLE 35 SQ.MM Cu	407083	S02-01-01-35			
4	1	CONNECTOR, PIERCING 150-50/35-6 SQ.MM	415586	S04-01-02-15			
3	AR	CABLE LV-ABC AL 4x95 SQ.MM	197665	S04-01-01-01			
2b	1	SUSPENSION CLAMP 4x95 SQ.MM	197681	S04-01-02-10			
2a		SUSPENSION CLAMP 4x95 SQ.MM ROLLER COMBO.	198408	S04-01-02-10			
1b	1	HOOK BOLT M16	197731	S04-01-02-07			
1a		HOOK BOLT M16 NON-BREAKAWAY ASSEMBLY	202184	S04-01-02-07			
ITEM	QTY	DESCRIPTION	ITEM NUMBER	DRG. REF.			
MATERIAL SCHEDULF							

AMENDMENTS											
NO	DESCRIPTION	DRN	DATE	CKD	APPD						
0	ISSUED FOR CONSTRUCTION	A.S.	APR'02	м.В.	F.R.R.						
1	ASSEMBLY REDRAWN, REFORMATTED NOTES, UPDATED NOTE 1. TITLEBLOCK & DRAWING NUMBERS FORMATTED	 K.⊺.	APR'19	c.c.	c.c.						
2	REFORMATTED TABLE. UPDATED ITEMS 4, 5, 6, 8, 9, 10, & 11. FUSE	A.N.	JUNE'21	A.N.	B.C.						
3	SUPERSEDED TO SO4-02-01-25	A.N.	SEP'21	A.N.	B.V.						

**PowerWater** NORTHERN TERRITORY

DRAFTING STANDARD TO A.S.1100			CAD PRODUCT - DO NOT AMEND MANUALLY	\ <u>\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\</u>		
ISSUED	AUG'01	A3	DRAWING NUMBER S01-02-01-29	$\sqrt{2}$		
SCALE	AS SHOWN		INTERMEDIATE SUSPENSION			
APPD	F.ROBSON	1 - 2 SERVICES				
CKD	M. BOCK		LV - ABC - BOLTED CONNECTIONS			
DRN	A. SCHMID		ASSEMBLIES			
DES	M.BOCK	POWER STANDARD DRAWING				
		Μ	IATERIAL SCHEDULE			

DRAFTING STANDARD TO A.S.1100 CAD PRODUCT - DO NOT AMEND MANUALLY