



PILLAR SIGN LAYOUT
SCALE N.T.S.

NOTES:

1. REFER TO S02-02-03-08 FOR PILLAR CONSTRUCTION DETAILS.
2. ITEM 4 ONLY REQUIRED FOR PILLARS HOUSING DESIGNED SYSTEM OPEN POINT.
3. ITEM 3 TO BE PLACED AT BOTH VERTICAL AND HORIZONTAL CENTERLINE OF THE PILLAR DOOR.

ITEM REF.	QTY.	DESCRIPTION	ITEM NUMBER	DRAWING REF.
4	1	RED REFLECTIVE STICKER INDICATING OPEN POINT	-	-
3	1	SIGN, DANGER TRIANGLE STICKER, 100MM	412498	S02-01-08-03
2	1	SIGN, PILLAR NUMBER	-	S02-01-08-30
1	1	5 SLOT STRIP TYPE FUSE PILLAR	292334	S02-02-03-08
MATERIAL SCHEDULE				

NO	DESCRIPTION	DRN	DATE	CKD	APPD
3	UPDATED ITEM 1 DESCRIPTION	A.N.	AUG'21	A.N.	B.V.
2	UPDATE ITEM 2 AND 4 DETAILS	C.C.	MAY'20	B.C.	B.V.
1	TITLEBLOCK & DRAWING NUMBER FORMATTED	K.T.	FEB'19	C.C.	C.C.
0	ISSUED FOR CONSTRUCTION	A.T.	APR'15	B.C.	B.C.
AMENDMENTS					



DES		POWER STANDARD DRAWING	
A.TAYLOR		SIGN, STRIPLE FUSE PILLARS	
DRN A.TAYLOR			
CKD B.CHEUNG			
APPD B.CHEUNG			
SCALE N.T.S.			
ISSUED NOVEMBER 2014		A3	DRAWING NUMBER S02-01-08-34
ALL DIM. IN mm			
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

