


NOTES :

1. ALL BOLTED CONNECTINS SHALL USE GALVANIZED STEEL BOLTS, SPRING WASHERS, LARGE FLAT WASHERS AND GALVANIZED NUTS.
2. GREASE SHALL BE USED ON ALL BOLTED CONNECTIONS.
3. FOR UNDERGROUND EARTHING REFER TO S01-02-03-11, S01-02-03-12 OR S01-02-03-13.

ITEM REF.	QTY.	DESCRIPTION	ITEM NUMBER	DRAWING REF.
8	4	GAIN BLOCK	-	-
7	AR	TREFOIL CABLE CLAMP	-	-
6	5	CROSSARM BRACE, 50x5 DURAGAL CF	298687	S01-01-04-38
5	1	ROUND POLE	-	-
4	9	CROSSARM, LV, TRANSFORMER AND CABLE TERMINATION, DURAGAL	298604	S01-01-02-12
3	1	CROSSARM, HV, STAND-OFF/SURGE ARRESTER, DURAGAL	298539	S01-01-02-10
2	1	CROSSARM, HV, EDO MOUNTING, FIBREGLASS	298547	S01-01-02-10
1	1	CROSSARM, HV, LINE/TERMINATION, FIBREGLASS	501656	S01-01-02-10

MATERIAL SCHEDULE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
10	UPDATED ITEM 1, REFORMATTED TABLE AND TEXT. OBSOLETE	A.N. C.C.	OCT'21 OCT'12	A.N. A.T.	B.V. B.C.
AMENDMENTS					



PowerWater
NORTHERN TERRITORY

DES	A.TAYLOR	POWER STANDARD DRAWING	
DRN	C.COPPINS	POLE STRUCTURES - ROUND POLE BOLTED CONNECTIONS HV CABLE TERMINATION	
CKD	A.TAYLOR		
APPD	B.CHEUNG		
SCALE	N.T.S.		
ISSUED	OCT'12	A3	DRAWING NUMBER S01-02-05-36
ALL DIM. IN mm			
DRAFTING STANDARD TO AS.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

