



NOTES:

1. REFER DRAWING No. S01-01-04-41 FOR FURTHER EYE NUT DETAILS.
2. PHASE SIGNS TO BE INSTALLED ON BOTH SIDES OF POLE. REFER TO DRAWING S02-01-08-13 FOR DETAILS.

ITEM	QTY	DESCRIPTION	ITEM NUMBER	DRG. REF.
8	4	PARALLEL GROOVE CLAMP TO SUIT CONDUCTOR	-	S01-01-04-25
7	2	M24 EYE NUT 18kN	298711	S01-01-04-41
6	2	HV SHACKLE STRAP STRAIN PLATE 100x6 DURAGAL CF	406938	S01-01-04-37
5	2	CROSSARM BRACE 50x5 DURAGAL CF	298687	S01-01-04-38
4	AR	OVERHEAD CONDUCTOR	-	S01-04-01-08
3	6	22kV POLYMER STRAIN/SUSPENSION INSULATOR 70kN	292656	S01-01-03-09
	6	TOUNGE HOOK 70kN	292680	S01-01-03-09
	6	THIMBLE CLEVIS 70kN	6767	S01-01-03-09
2	3	22kV CYCLOALIPHATIC LINE POST INSULATOR	300467	S01-01-03-10
1	1	CROSSARM HV - 125x125x6 SQUARE HOLLOW FIBREGLASS	414398	S01-01-02-10

MATERIAL SCHEDULE

NO	DESCRIPTION	DRN	DATE	CKD	APPD
4	DIAGRAM AND TEXT ROTATED TO ALIGN WITH REST OF DRAWING, ADDED PHASE IDENTIFICATION SIGN DRAWING REFERENCE. UPDATED INSULATORS.	R.A.	OCT'21	C.C.C.	B.V.
3	REFORMATTED TABLE AND NOTES. UPDATED ITEMS 1, 2, 3, 4, 5, 6, 7 & 8. UPDATED NOTE 1 DRAWING REFERENCE.	A.N.	JUL'21	A.N.	B.C.
2	TITLEBLOCK & DRAWING NUMBERS FORMATTED	K.T.	JAN'19	C.C.	C.C.
1	UPDATED CROSS ARM	C.C.	OCT'11	A.T.	S.C.
0	ISSUED FOR CONSTRUCTION	A.S.	25.10.01	M.B.	F.R.R.

PowerWater
NORTHERN TERRITORY

DES	M. BOCK	POWER STANDARD DRAWING	
DRN	A. SCHMID	POLE TOP UNITS HV TRANSPOSITION FOR UNIVERSAL POLE CONSTRUCTION	
CKD	M. BOCK		
APPD	F. ROBSON		
SCALE	1:20 (ON A3)	A3	DRAWING NUMBER S01-02-02-35
ISSUED	OCT '01		
ALL DIM.	IN mm	DRAWING NUMBER S01-02-02-35	
DRAFTING STANDARD TO A.S.1100		CAD PRODUCT - DO NOT AMEND MANUALLY	

